

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 3295-0577:002 Page 1 of 1

**CATEGORY:** Fire-Rated Door

**LISTEE:** Republic Builders Products, PO Box 580, McKenzie TX 38201  
Contact: Craig J Ordmandy (731) 352-3383\*

**DESIGN:** Model 638 series and Models DE820 and DE818. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, rating and UL label.

**APPROVAL:** Listed as a 1½-hour (B) fire-rated door when installed in a frame approved for the wall construction and when equipped with fire-rated hardware.

**NOTE:** Formerly 3375-0577:002

\*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager